

BOREHOLE WATER TEST CERTIFICATE


304



Arena Group

Group of Companies

www.arenagroup.co.za 086 999 0823



CLIENT: . PTN 11 1238 HOOGKRAAL

BOREHOLE NO: 1

LOCATION: S34°02.4735" E 22°18.1961"

ADDRESS: GLENTANA , DATE: 13/5/2019
WESTERN CAPE

CASING DIAMETER: mm 155 STEEL PVC:

BOREHOLE DEPTH: 115 M

BOREHOLE PUMP TEST DEPTH: 110 M

STATIC WATER LEVEL: 20.7 M

DURATION OF TEST: 6 HOURS

TEST PUMP: 2.2 KW

YIELD: 2860 L/Hour / 0.79 L/S

DYNAMIC WATER LEVEL DURING TEST: 25.8 M

RECOVERY TIME TO STATIC LEVEL: 10 MIN

COMMENTS/ADVICE:

SIGNATURE

TECHNICIAN/NAME: A - OBERHOLZER
MEMBERSHIP NO: 099